## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7125-1076:157 Page 1 of 1

**CATEGORY**: Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721

Contact: Terrill Garland (508) 881-2000 FAX (508) 881-1773

**DESIGN:** Models RSS-241575W, RSSP-241575W, \*RSS-24MCW and \*RSSP-24MCW

synchronized or non-synchronized Strobe Lights. Model number may be followed by any two alpha/numeric characters indicating lens orientation, lettering and color. Refer to

listee's data sheet for additional detailed product description and operational

considerations.

RATING: Electrical 20-31 VDC/FWR

\*RSS-24MCW, RSSP-24MCW: 16-33 VDC/FWR

Candela 1575=15/75cd on axis

\*RSS-24MCW, RSSP-24MCW: selectable 15cd, 30cd, 75cd or 110cd

Flash rate 60 Flashes/minute

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction. Models are intended for

wall mount only.

**MARKING:** Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe light suitable for the hearing impaired when used in conjunction with

separately listed electrically compatible fire alarm control units. For indoor use only. For synchronization strobes, Models SM-12/24, DSM-12/24, Sync Control Module (CSFM Listing

No. 7300-1076:153) must be used.

**XLF:** 7125-0785:141

\*Rev. 09-02-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 22, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager